

No.DY212543



中国认可
国际互认
检测
TESTING
CNAS L0153

TEST REPORT

Name of product 18/30 (36) kV Screened separable connector

Type Specification GCA CJB30-630 1×300

Applicant GCA Co., Ltd.

Testing category Type Tests



**GUANGDONG TESTING INSTITUTE OF PRODUCT QUALITY SUPERVISION
(GQI)**

DECLARATION

1. Tampering with this report in computer will be recorded by e-signature and shown that the report has been modified. And this report will be invalid. The test report is invalid if scribbled or altered. It is invalid without the official testing stamp of the institute. It is invalid without signatures or stamps of the testing, reviewed and approved persons.
2. The validity of this report can be verified online by logging into the website of China National Quality Supervision and Testing Center for Smart Grid Transmission and Distribution Equipment (<http://www.cest.asia>). Except when the applicant declares that the report information is not disclosed.
3. The electronic report shall be valid on that it is issued within the validity period of the e-signed certificate and it is not shown to have been modified or updated. Any partial photocopy of the test report is not allowed without written permission of the testing institute.
4. Any dispute of the test result must be raised to the testing institute within 15 days after receiving, otherwise it is taken as no objection (except otherwise stipulated).
5. The result of commission test relates only to the sample(s) tested.
6. The test result and test report shall not be used as improper or illegal propaganda.
7. The validity of e-signature requires manually adding certificate trust. Adding certificate trust operation: click signature attribute - click show certificate - click trust - click add to trusted identity - click all - click ok - click verify signature.

Guangdong Testing Institute of Product Quality Supervision

TEST REPORT

Page 1 of 49

Name of product	18/30 (36) kV Screened separable connector	Date of manufacturing / expiry	____/____
Type, Specification, Trade mark, Class	GCA CJB30-630 1×300	Batch No.	____/____
Inspected unit	_____	No. of testing / sampling plan	YDY21/000657/ _____
Address of inspected unit	_____	Testing category	Type Tests
Applicant	GCA Co., Ltd.	Location of sampling	_____
Manufacturer	GCA Co., Ltd.	Basic quantity of sampling	_____
Address of Manufacturer	19th, South Road 4, Guicheng, Nanhai District, Foshan City, Guangdong Province, China	Way of sample incoming Personnel performing sending / sampling	Customer Sampling Sending (Long Liying)
Quantity of sample	8 pcs	Date of receipt of sample / sampling	2021-06-29/ _____
Status of sample	Good condition	Date(s) of performance of tests	2021-07-02 to 2021-08-18
Testing reference	IEC 60502-4:2010 Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m=1,2$ kV) up to 30 kV ($U_m=36$ kV) – Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m=7,2$ kV) up to 30 kV ($U_m=36$ kV).		
Judgment reference	IEC 60502-4:2010 Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m=1,2$ kV) up to 30 kV ($U_m=36$ kV) – Part 4: Test requirements on accessories for cables with rated voltages from 6 kV ($U_m=7,2$ kV) up to 30 kV ($U_m=36$ kV). Consigner's technical requirements.		
Conclusion	<p>The samples were tested according to the testing standards and product technical specifications. All items were tested positive.</p> <p>Official testing stamp of the institute Date of issue 2021-09-01</p>		
Notes	The 18/30 (36) kV screened separable connector equipped with mechanical cable lug.		

Approved by:

Reviewed by:

Tested by:

TEST REPORT

Catalogue		
Contents		Page
Homepage		1
Catalogue		2
Descriptions of samples, test cables and test circuits		3~4
Test items and results summary		5~6
Test sequence 4.1	AC voltage (dry test)	7
	DC voltage (dry test)	8
	Partial discharge (at ambient temperature)	9
	Impulse (at the maximum cable conductor temperature in normal operation +5 K to 10 K)	10
	Heating cycles in air	11
	Heating cycles under water	12
	Disconnect/connect	13
	Partial discharge (at ambient temperature)	14
	Partial discharge (at the maximum cable conductor temperature in normal operation +5 K to 10 K)	15
	Impulse (at ambient temperature)	16
	AC voltage (dry test)	17
	Examination	18
	Test sequences 4.2, 4.3	AC voltage (dry test)
DC voltage (dry test)		20
Thermal short-circuit (screen)		21
Thermal short-circuit (conductor)		22
Dynamic short-circuit		23
Disconnect/connect		24
Impulse (at ambient temperature)		25
AC voltage (dry test)		26
Examination		27
Screen resistance		28
Screen leakage current		29
Appendix		30~47
List of main test equipments		48
Notions		49

TEST REPORT

Descriptions of samples, test cables and test circuits		
Description of samples		
Name		18/30 (36) kV Screened separable connector
Model		GCA CJB30-630 1×300
Rated voltage, U ₀ /U (U _m) (kV)		18/30 (36)
No. of cores		Single-core
Description of test cables		
Rated voltage, U ₀ /U (U _m) (kV)		18/30 (36)
Structure	No. of cores	Single-core
	Screen structure	Phase separation shielding
Conductor	Material	Aluminium
	Shape	Compact circular stranding
	Cross-section	300 mm ²
	External diameter	20.5 mm
Insulation	Material	XLPE
	Thickness	8 mm
	External diameter	38.6 mm
Maximum cable conductor temperature in normal operation		90 °C
Maximum permissible short-circuit temperature of cable		250 °C
Screen	Conductor screen thickness	1 mm
	Insulation screen thickness	0.5 mm
	Whether the insulation shield can be stripped	Non strippable
	Insulation screen external diameter	39.6 mm
	Metallic screen	Copper wire
Armour		None
Outer sheath	Material	PE
	External diameter	47.1 mm
Cable marking		NA2XS (F) 2Y 1×300/25
Cable Mamufacturer		SYNERGY CABLES LTD.

TEST REPORT

Descriptions of samples, test cables and test circuits

Description of test circuits

Test sequence 4.1	Loop 1#	Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-1) + Bushing + Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-2)
	Loop 2#	Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-3) + Bushing + Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-4)
Test sequences 4.2, 4.3	Loop 3#	Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-5)
	Loop 4#	Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-6)
	Loop 5#	Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-7)
Screen resistance and Screen leakage current	Loop 6#	Cold shrinkable termination (Cooperation test) + Cable + 18/30kV Screened separable connector (8-8)

Note:

Before the type tests, a calibration cable with a length of 2 m and the same specification as the test cable was sent by the manufacturer, to determine the conductor temperature by direct measurement for a given current, within the temperature range required for the test (at the maximum cable conductor temperature in normal operation +5 K to 10 K). Method A.3.1 in annex A of IEC 61442 was used as a guide.

Calibration result

Current	765 A
Cable conductor temperature	97.5 °C
Ambient temperature	32.0 °C

TEST REPORT

Test items and results summary			
No.	Test items	Test Requirement	Result
Test sequence 4.1			
1	AC voltage (dry test)	81 kV (4.5 U_0), 5 min	Pass
2	DC voltage (dry test)	72 kV (4 U_0), 15 min	Pass
3	Partial discharge (at ambient temperature)	30 kV (1.73 U_0), ≤ 10 pC	Pass
4	Impulse (at the maximum cable conductor temperature in normal operation +5 K to 10 K)	Power cable temperature: (95~100) °C 170 kV, 10 impulses of each polarity	Pass
5	Heating cycles in air	Power cable temperature: (95~100) °C 45 kV (2.5 U_0), 30 cycles (8 h total with ≥ 2 h steady and ≥ 3 h cooling)	Pass
6	Heating cycles under water	Power cable temperature: (95~100) °C 45 kV (2.5 U_0), 30 cycles (8 h total with ≥ 2 h steady and ≥ 3 h cooling), water height 1 m	Pass
7	Disconnect/connect	Five times. No visible damage to contact	Pass
8	Partial discharge (at ambient temperature)	30 kV (1.73 U_0), ≤ 10 pC	Pass
9	Partial discharge (at the maximum cable conductor temperature in normal operation +5 K to 10 K)	Power cable temperature: (95~100) °C 30 kV (1.73 U_0), ≤ 10 pC	Pass
10	Impulse (at ambient temperature)	170 kV, 10 impulses of each polarity	Pass
11	AC voltage (dry test)	45 kV (2.5 U_0), 15 min	Pass
12	Examination	See page 18	Pass
Test sequences 4.2, 4.3			
13	AC voltage (dry test)	81 kV (4.5 U_0), 5 min	Pass
14	DC voltage (dry test)	72 kV (4 U_0), 15 min	Pass
15	Thermal short-circuit (screen)	Power cable temperature: (95~100) °C I_{sc} : 3.5 $^{+5\%}_0$ kA/1s, two short-circuits	Pass
16	Thermal short-circuit (conductor)	I_{sc} : 24.5 $^{+5\%}_0$ kA/2s, two short-circuits	Pass
17	Dynamic short-circuit	I_d : 86.7 $^{+5\%}_0$ kA, ≥ 10 ms	Pass

TEST REPORT**Test items and results summary**

No.	Test items	Test Requirement	Result
18	Disconnect/connect	Five times. No visible damage to contact	Pass
19	Impulse (at ambient temperature)	170 kV, 10 impulses of each polarity	Pass
20	AC voltage (dry test)	45 kV (2.5 U ₀), 15 min	Pass
21	Examination	See page 27	Pass
Screen resistance, Screen leakage current			
22	Screen resistance	Before and after thermal aging (120°C, 168 h) ≤ 5 kΩ	Pass
23	Screen leakage current	36 kV (U _m), ≤ 0.5 mA.	Pass

Test sequence 4.1			Impulse (at the maximum cable conductor temperature in normal operation +5 K to 10 K)								
Ambient temperature: 31.3 °C, Humidity: 75 %, Atmos: 100.5 kPa Date of Test: 2 July, 2021											
Testing arrangement	Voltage applied to	Earth connected to	Polarity	Applied voltage (peak) (kV)	Actual applied voltage (peak) (kV)	No.	Test conditions				
Main circuit to earth	Loop 1#	Metallic screen	Positive	170	169.42~170.76	10	No breakdown, No flashover				
			Negative	170	169.98~174.28	10	No breakdown, No flashover				
	Loop 2#	Metallic screen	Positive	170	165.48~170.60	10	No breakdown, No flashover				
			Negative	170	170.16~171.93	10	No breakdown, No flashover				
Note: 1. Stable conductor temperature 97.5 °C 2. Actual applied voltage (peak) (kV)											
Loop 1#	Positive	169.97	170.31	169.42	169.56	170.04	169.69	170.23	170.76	169.97	170.31
	Negative	173.59	170.26	171.63	174.28	170.75	171.55	169.98	171.22	173.59	170.26
Loop 2#	Positive	165.48	170.18	170.60	169.77	170.42	170.18	170.21	169.83	165.48	170.18
	Negative	170.62	170.82	171.93	170.58	171.23	170.64	171.03	170.16	170.62	170.82
3. Impulse typical oscillograms (see appendix) L21-DY0656-S01~L21-DY0656-S04											
Result The test was passed.											

Heating cycles in air

No. of heating cycles	Require stable conductor temperature (°C)	Heating current (A)	Heating per cycle		Cooling per cycle	Voltage per cycle	
			Total duration (h)	Duration of conductor at stable temperature (h)	Total duration (h)	Total duration (h)	Applied voltage (RMS) $1.73U_0$ (kV)
30	95~100	765	5	2	3	8	45

Loop 1# + Loop 2#
97.5 °C

The test was passed, during the test, no breakdown and flashover occurred.

TEST REPORT

Test sequence 4.1		Disconnect/connect	
Ambient temperature: 30.8 °C, Humidity: 70 %		Date of Test: 9 August, 2021	
Samples of disconnect/connect	No. of disconnect/connect	Requirement	Observations
Loop 1#	5	No visible damage to contact	Complied
Loop 2#	5	No visible damage to contact	Complied
Result The test was passed.			

TEST REPORT

Test sequence 4.1		Partial discharge (at ambient temperature)				
Ambient temperature: 30.4°C ,		Humidity: 76 % ,		Atmos: 100.6 kPa		Date of Test: 10 August, 2021
Testing arrangement	Voltage applied to	Earth connected to	Applied voltage (RMS) 1.73U ₀ (kV)	Actual applied voltage (RMS) (kV)	Partial discharge level (pC)	Requirement (pC)
Main circuit to earth	Loop 1#	Metallic screen	30	30.2	< 3	≤ 10
	Loop 2#	Metallic screen	30	30.1	< 3	≤ 10

Note:

1. Ambient noise < 1 pC
2. The test was carried out at ambient temperature.

Result

The test was passed.

AC voltage (dry test)

Testing arrangement

Earth
connected to

Applied
voltage
(RMS)
 $2.5U_0$ (kV)

Actual
applied
voltage
(RMS)
(kV)

Duration
(min)

Test conditions

Main circuit to earth

Loop 1#

Metallic
screen

45

45.0

15

No breakdown, No flashover

Loop 2#

Metallic
screen

45

45.0

15

No breakdown, No flashover

The test was passed.

TEST REPORT

Test sequence 4.1	Examination	
Ambient temperature: 30.4 °C, Humidity: 76 %, Atmos: 100.6 kPa Date of Test: 10 August, 2021		
Test objects	Requirement	Observations
8-1~8-4 Screened separable connectors	No cracking in the filling media and/or tape or tube components;	Complied
	No moisture path across a primary seal;	Complied
	No corrosion and/or tracking and/or erosion;	Complied
	No leakage of any insulating material.	Complied
<div>Result</div> <div>The test was passed.</div>		

TEST REPORT

Test sequences 4.2, 4.3		Thermal short-circuit (screen)						
Ambient temperature: 31.5 °C, Humidity: 66 %,					Date of Test: 8 July, 2021			
No. of short-circuit	Test loop	Test current (A)			Duration (s)	Oscillogram No.	Requirement	Observations
		I _a	I _b	I _c				
1 st	A: Loop 3# (screen) B: Loop 4# (screen) C: Loop 5# (screen)	3642	3573	3565	1.04	D21E-DY0656-S4	No visible deterioration	Complied
2 nd	A: Loop 3# (screen) B: Loop 4# (screen) C: Loop 5# (screen)	3629	3605	3596	1.04	D21E-DY0656-S5		

Note:

1. Before the test, stable conductor temperature was 97.5 °C with 2 h steady.
2. Thermal short-circuit (screen) oscillograms see appendix.

Result

The test was passed.

TEST REPORT

Test sequences 4.2, 4.3		Thermal short-circuit (conductor)						
Ambient temperature: 31.5 °C, Humidity: 66 %,					Date of Test: 8 July, 2021			
No. of short-circuit	Test loop	Test current (kA)			Duration (s)	Oscillogram No.	Requirement	Observations
		I _a	I _b	I _c				
1 st	A: Loop 3# (conductor) B: Loop 4# (conductor) C: Loop 5# (conductor)	25.2	25.1	25.4	2.03	D21E-DY0656-S2	No visible deterioration	Complied
2 nd	A: Loop 3# (conductor) B: Loop 4# (conductor) C: Loop 5# (conductor)	25.0	25.0	25.4	2.01	D21E-DY0656-S3		

Note:

1. The test was carried out at ambient temperature.
2. Thermal short-circuit (conductor) oscillograms see appendix.

Result

The test was passed.

TEST REPORT

Test sequences 4.2, 4.3		Dynamic short-circuit			
Ambient temperature: 31.5 °C, Humidity: 66 %,				Date of Test: 8 July, 2021	
Test loop	Test current (peak) (kA) I_d	Duration (ms)	Oscillogram No.	Requirement	Observations
A: Loop 3# (conductor) B: Loop 4# (conductor) C: Loop 5# (conductor)	90.0	31.0	D21E-DY0656-S1	No visible deterioration	Complied
Note: 1. The test was carried out at ambient temperature. 2. Dynamic short-circuit oscillogram see appendix. Result The test was passed.					

TEST REPORT

Test sequences 4.2, 4.3		Disconnect/connect	
Ambient temperature: 31.0 °C,		Humidity: 68 %,	Date of Test: 12 July, 2021
Samples of disconnect/connect	No. of disconnect/connect	Requirement	Observations
Loop 3#	5	No visible damage to contact	Complied
Loop 4#	5	No visible damage to contact	Complied
Loop 5#	5	No visible damage to contact	Complied

Result

The test was passed.

TEST REPORT

Test sequences 4.2, 4.3			Impulse (at ambient temperature)				
Ambient temperature: 33.1 °C, Humidity: 62 %, Atmos: 100.6 kPa			Date of Test: 13 July, 2021				
Testing arrangement	Voltage applied to	Earth connected to	Polarity	Applied voltage (peak) (kV)	Actual applied voltage (peak) (kV)	No.	Test conditions
Main circuit to earth	Loop 3#	Metallic screen	Positive	170	170.20~173.54	10	No breakdown, No flashover
			Negative	170	166.53~174.83	10	No breakdown, No flashover
	Loop 4#	Metallic screen	Positive	170	170.55~173.27	10	No breakdown, No flashover
			Negative	170	167.74~174.83	10	No breakdown, No flashover
	Loop 5#	Metallic screen	Positive	170	169.56~172.85	10	No breakdown, No flashover
			Negative	170	167.74~174.83	10	No breakdown, No flashover

Note:

1. Actual applied voltage (peak)

(kV)

Loop 3#	Positive	170.96	173.24	173.54	172.73	170.20	171.79	171.79	172.85	172.63	172.54
	Negative	166.53	167.74	173.46	172.57	174.83	170.66	170.57	172.11	172.64	172.46
Loop 4#	Positive	172.83	171.67	172.80	172.26	172.57	173.27	170.55	170.76	171.67	172.57
	Negative	171.79	171.02	172.17	173.78	174.83	170.66	169.90	172.11	167.74	169.71
Loop 5#	Positive	169.93	170.31	170.76	169.69	172.29	171.17	172.21	171.79	172.85	169.56
	Negative	170.58	170.64	170.82	170.26	170.75	169.98	167.74	173.46	174.83	168.72

2. Impulse typical oscillograms (see appendix) L21-DY0656-S09~L21-DY0656-S14

3. The test was carried out at ambient temperature.

Result

The test was passed.

TEST REPORT

Test sequences 4.2, 4.3		Examination	
Ambient temperature: 32.0 °C, Humidity: 66 %		Date of Test: 13 July, 2021	
Test objects	Requirement	Observations	
8-5~8-7 Screened separable connectors	No cracking in the filling media and/or tape or tube components;	Complied	
	No moisture path across a primary seal;	Complied	
	No corrosion and/or tracking and/or erosion;	Complied	
	No leakage of any insulating material.	Complied	
<div>Result</div> <div>The test was passed.</div>			

TEST REPORT

Screen resistance		
Ambient temperature: (27.5~32.3) °C, Humidity: 58 %~69 % Date of Test: 19 July, 2021~26 July, 2021		
Test objects	Requirement	Measurement
8-8 Screened separable connector	Before thermal ageing, screen resistance	$\leq 5 \text{ k}\Omega$ 369 Ω
	Thermal ageing test temperature	120 °C \pm 2 °C
	Thermal ageing test duration	168 h
	After thermal ageing, screen resistance	$\leq 5 \text{ k}\Omega$ 324 Ω
Result The test was passed.		

TEST REPORT**Screen leakage current**

Ambient temperature: 33.1 °C, Humidity: 65 %, Atmos: 100.5 kPa

Date of Test: 15 July, 2021

Testing arrangement	Voltage applied to	Earth connected to	Applied voltage (RMS) U_m (kV)	Actual applied voltage (RMS) (kV)	Requirement	Measurement
Main circuit to earth	Loop 6#	Screened separable connector + Metallic screen	36	36.1	≤ 0.5 mA	≤ 0.01 mA

Result


The test was passed.

TEST REPORT

Appendix	
1. Assembly drawing	
18/30 (36) kV Screened separable connector GCA CJB30-630 assembly drawing.	
2. Photos	
20 photos in total	
3. Test circuit diagrams	
AC voltage test circuit diagram;	
DC voltage test circuit diagram;	
Impulse test circuit diagram;	
Thermal short-circuit and dynamic short-circuit test diagram.	
4. Oscillograms	
Impulse typical oscillograms	L21-DY0656-S01~L20-DY0656-S14
Dynamic short-circuit oscillograms	D21E-DY0656-S1
Thermal short-circuit (conductor) oscillograms	D21E-DY0656-S2, D21E-DY0656-S3
Thermal short-circuit (screen) oscillograms	D21E-DY0656-S4, D21E-DY0656-S5







TEST REPORT

Assembly drawing








				GCA CJB30-630		Assembly drawing			
标记	处数	更改文件号	签字	日期	18/30 (36) kV	图样标记	数量	重量	比例
设计	杨志华	标准化	吴春玲		Screened Separable connector				1:2
审核	杨志华	批准	吴春玲		材料	共	张	第	张
工艺		日期	2021.8			GCA			

TEST REPORT

Photos of samples	
	
8-1~8-2	8-3~8-4
	
8-5	8-6
	
8-7	8-8

TEST REPORT

Photos of tests	
	
AC voltage	DC voltage
	
Partial discharge	Impulse
	
Screen leakage current	

TEST REPORT

Photos of tests



Heating cycles in air



Heating cycles under water

TEST REPORT


Photos of tests



Thermal short-circuit (screen)



Before test



After test

TEST REPORT

Photos of tests



Thermal short-circuit (conductor) and Dynamic short-circuit




Before test



After test

TEST REPORT


AC voltage test circuit diagram



AT: Voltage regulator TT: Power frequency transformer V₁: Voltmeter A: Ammeter
R_p: Protective resistance TO: Test object C₁: HV arm capacitance C₂: LV arm capacitance
V₂: Peak voltmeter

TEST REPORT


DC voltage test circuit diagram



T: Voltage regulator D1, D2: Rectifier element C_1, C_2 : Generator capacitance V: Voltmeter
 R_P, R_S : Protective resistance TO: Test object R_1 : HV arm resistance R_2 : LV arm resistance

TEST REPORT


Impulse test circuit diagram



C_1 : Generator capacitance	g_1 : Discharge gap	R_{S1} : Internal series resistance	R_{S2} : Front resistance
R_P : Tail resistance	C_L : Load capacitance	Z_1, Z_2 : Voltage divider impedance	TO: Text object

TEST REPORT

Thermal short-circuit and dynamic short-circuit test diagram





QF : Master breaker
L : Reactor
R : Resistor
TM : Test power supply

HK : Making switch
I : Current measurement
U : Voltage measurement
SP : Test specimen



TEST REPORT

Impulse typical oscillograms

Loop 1# (before heating cycles in air):



Loop 2# (before heating cycles in air):



V


TEST REPORT

Impulse typical oscillograms

Loop 1# (after heating cycles unde water):



(170kV Positive) L21-DY0656-S05




(170kV Negative) L21-DY0656-S06

Loop 2# (after heating cycles unde water):



(170kV Positive) L21-DY0656-S07




(170kV Negative) L21-DY0656-S08


TEST REPORT

Impulse typical oscillograms

Loop 3# (after thermal and dynamic short-circuit):



(170kV Positive) L21-DY0656-S09




(170kV Negative) L21-DY0656-S10

Loop 4# (after thermal and dynamic short-circuit):



(170kV Positive) L21-DY0656-S11



(170kV Negative) L21-DY0656-S12


TEST REPORT

Impulse typical oscillograms

Loop 5# (after thermal and dynamic short-circuit):




(170kV Positive) L21-DY0656-S13



(170kV Negative) L21-DY0656-S14

TEST REPORT

Dynamic short-circuit oscillograms




Dynamic short-circuit

conductor
Idy

$I_p=90.0\text{kA}$


Duration:31.0ms

D21E-DY0656-S1



TEST REPORT

Thermal short-circuit (screen) oscillograms



Thermal short-circuit
(screen)

screen
lth-1

I_a=3642A
I_b=3573A
I_c=3565A

I_p=5771A

I²t=14.1MA²s

Duration: 1.04s

D21E-DY0656-S4

screen
lth-2

I_a=3629A
I_b=3605A
I_c=3596A

I_p=5771A

I²t=13.9MA²s

Duration: 1.04s

D21E-DY0656-S5

TEST REPORT

List of main test equipments			
Cl.	Device name	No. of equipment	Term of validity
1	Air pressure meter	03041	2021-08-19
2	Alarm digital hygrothermograph	C24E052	2021-12-09
3	Power-frequency testing transformer without PD	C28G351	2022-05-20
4	Impulse voltage generator	Ac.03Fw001	2021-08-24
5	Multichannel digital PD integrative analysis system	C24E089	2021-09-07
6	Calibration pulse generator	C24F003	2022-04-22
7	DC high-voltage generator	C28G269	2021-08-25
8	Electric parameter detector	C28E049-01	2022-03-08
9	Digital multimeter	24194	2022-07-12
10	Heating cycles system	C24G199	2021-12-24
11	Heating cabinet	03037	2023-03-08
12	Instantaneous recorder	C28E032-02	2021-12-24
13	Data acquisition recorder	C24E004-02	2021-12-15

TEST REPORT

Notions:

- 1. Testing location/ address: No.68, XiHu East Road, ShiLong Town, Dongguan City, Guangdong Province, China
- 2. Address of applicant: 19th, South Road 4, Guicheng, Nanhai District, Foshan City, Guangdong Province, China
- 3. Environmental conditions (if applicable):
Temperature (25.0~32.0) °C, Humidity 55%~72%, Other
- 4. Sampling procedure (if applicable):
- 5. The interpretation of the deviation(s) from standard method(s) (if applicable):
- 6. The interpretation of the measurement uncertainty of the result(s) (if applicable):
- 7. Subcontract items and subcontractor (if applicable):



广东产品质量监督检验研究院

GUANGDONG TESTING INSTITUTE OF PRODUCT QUALITY SUPERVISION

Guangdong Testing Institute of Product Quality Supervision (In Short GQI), also called Guangzhou Electrical Safety Testing Institute, Guangdong Testing and Certification Institute, was set up in September, 1983. It is a public institution affiliated to Guangdong Administration for Market Regulation (Administration for Intellectual Property).

GQI is a legal third party institute specializing in product testing, inspection and certification; it is subordinate to Guangdong Administration for Market Regulation (Administration for Intellectual Property); it is a national-level testing and inspecting organization accredited by China National Accreditation Service for Conformity Assessment (CNAS); it is an international CB testing laboratory recognized by International Electro-technical Commission System for Conformity Testing and Certification of Electro-technical Equipment and Components(IECEE); it is the national compulsory CCC testing organization designated by Certification and Accreditation Administration of the People's Republic of China(CNCA).

GQI currently undertakes commitment of 10 national supervision and testing centers, which are:

- ▼ China National Quality Supervision and Testing Center for Safety of Electrical Products China National Quality Supervision and Testing Center for Furniture (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Smart Grid Transmission and Distribution Equipment(CEST)
- ▼ China National Quality Supervision and Testing Center for Paintings and Dopes (Guangdong)
China National Quality Supervision and Testing Center for Food (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Machinery Safety
- ▼ China National Quality Supervision and Testing Center for Fire Fighting Products (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Solar Energy Photovoltaic Products (Guangdong)
- ▼ China National Quality Supervision and Testing Center for Cables and Wires (Guangdong)
China National Quality Supervision and Testing Center for Industrial Robots (Guangdong)

The Mark of Conformity



The Assurance of Quality

Head Quarter

Add.: No.10, Science Avenue, Science City, Huangpu
District, Guangzhou, Guangdong, China

Tel.: (86) 20 89232806

Fax: (86) 20 89232876

Web: www.gqi.org.cn

P. C. : 510670

E-mail: gqi@gqi.org.cn

Pazhou Base

Add.: No.6, Haicheng East Street, Xingang East Road,
Haizhu District, Guangzhou, Guangdong, China

Tel.: (86) 20 89237161

Fax: (86) 20 32315826

Web: www.gqi.org.cn

P. C. : 510330

E-mail: gqi@gqi.org.cn

Shunde Base

Add.: No.1, Desheng East Road, Daliang New Town Zone,
Shunde District, Foshan, Guangdong, China

Tel.: (86) 757 22808888

Fax: (86) 757 22802666

Web: www.sdgqi.cn

P. C. : 528300

E-mail: sdgqi@gqi.org.cn

Dongguan Base

Add.: No.68, Xihu East Road, Shilong, Dongguan,
Guangdong, China

Tel.: (86) 769 81867878

Fax: (86) 769 86106166

Web: www.cest.asia

P. C. : 523325

E-mail: cest@cest.asia

Guzhen Sub-Branch

Add.: 1st Fl.of Bldg.5, No.106, Pinghe Road,Tongyi Industrial
Park,Guzhen Town, Zhongshan , Guangdong, China

Tel.: (86) 760 22395898

Fax: (86) 760 22397968



广东质检院官方微信公众号